

I.S. EN ISO 9972:2015 – Thermal Performance of Air Permeability
Determination of Air Permeability of Buildings
(Single and Multi) Fan Pressurization Test Method B
Final Report

**16 Owenmore Paddock,
Ballynacarrow,
Co Sligo.**

Results

Air Permeability Reading: **0.5982 m³.hr.m² @50 Pascals**

Air Changes: **0.60 air changes per hour**

